**Facility DEC ID: 2620600032**

**PERMIT**
**Under the Environmental Conservation Law (ECL)**

**IDENTIFICATION INFORMATION**

Permit Type: Air State Facility
Permit ID: 2-6206-00032/00004
Effective Date: Expiration Date:

Permit Issued To:NYC HEALTH & HOSPITALS CORP
125 Worth St
New York, NY 10013-4006

Contact: YUNJUNG LEE
NYC-HH BELLEVUE HOSPITAL
462 1ST AVE
NEW YORK, NY 10016

Facility: NYC-HH - NEW BELLEVUE HOSPITAL-462 1 AV
462 FIRST AVE
NEW YORK, NY 10016

Contact: YUNJUNG LEE
NYC-HH BELLEVUE HOSPITAL
462 1ST AVE
NEW YORK, NY 10016

Description:
The facility, NYC-HH - NEW BELLEVUE HOSPITAL-462 1 AV, is located at 462 First Ave, New York, New York. NYC HHC Bellevue Hospital currently operates under a state facility permit. Under this renewal, the facility will operate the following:

- Two (2) Caterpillar G3516H CHP engines (Emission Sources J0007 and J0008) rated at 1982 kW each and firing natural gas only. The emission sources are equipped with selective catalytic reduction (SCR) and oxidation catalyst emission controls. Engines are subject to the requirements of 40 CFR 60 Subpart JJJJ - Standards of Performance for Stationary Spark Ignition Internal Combustion Engines.

Exempt sources include:

Stationary Combustion Installations
- Four (4) Caterpillar C27 emergency engine generators, rated at 750 kW each
- One (1) Caterpillar 3512C emergency engine generator, rated at 1500 kW
- One (1) Cummins DFHD-5622268 emergency engine generator, rated at 1000 kW
- Two (2) Caterpillar D399 emergency engine generator, rated at 600 kW each
- One (1) MTU 16V40000 DS20000 emergency engine generator, rated at 2000 kW (new installation)

Fuel oil storage tanks
- Five (5) 15,000 gallon underground storage tanks
- Three (3) 275 gallon above ground storage tanks

**Facility DEC ID: 2620600032**

The following changes are incorporated in this permit renewal:
- All engine generators are withdrawn from demand reponse programs and are either decomissioned or emergency operation only. Emission Unit U-00001 and it's Emission Sources, 0S001, 0S002, 0S003, 0S004, 0S005, 0S006, and 0S007 are exempt and removed from permit.
- One (1) Rudox RM900S 600 kW engine generator decomissioned.
- Two (2) Caterpillar G3516H CHP engine installed.
- One (1) MTU 16V40000 DS20000 emergency engine generator installed.

The facility NOx emissions are capped at 24.9 tons per year.

Records demonstrating compliance with this cap will be kept in accordance with the permit specific conditions.

The facility is subject to the provisions of State Facility requirements specified under 6NYCRR 201-5.

The Air State Facility permit contains a listing of the applicable federal, state, and compliance monitoring requirements for the facility.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: CAITLYN P NICHOLS
1 HUNTERS POINT PLAZA
47-40 21ST ST
LONG ISLAND CITY, NY 11101

Authorized Signature: _____ Date: ___ / ___ / _____

## Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.

## PAGE LOCATION OF CONDITIONS

**PAGE**

**DEC GENERAL CONDITIONS**

**General Provisions**

5 1 Facility Inspection by the Department

5 2 Relationship of this Permit to Other Department Orders and Determinations

5 3 Applications for permit renewals, modifications and transfers

6 4 Permit modifications, suspensions or revocations by the Department

**Facility Level**

6 5 Submission of application for permit modification or renewal - REGION 2 HEADQUARTERS

## DEC GENERAL CONDITIONS
****** General Provisions ******
**GENERAL CONDITIONS - Apply to ALL Authorized Permits.**

**Condition 1: Facility Inspection by the Department**
**Applicable State Requirement: ECL 19-0305**

**Item 1.1:**
The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

**Item 1.2:**
The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

**Item 1.3:**
A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

**Condition 2: Relationship of this Permit to Other Department Orders and Determinations**
**Applicable State Requirement: ECL 3-0301 (2) (m)**

**Item 2.1:**
Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

**Condition 3: Applications for permit renewals, modifications and transfers**
**Applicable State Requirement: 6 NYCRR 621.11**

**Item 3.1:**
The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 3.2:**
The permittee must submit a renewal application at least 180 days before the expiration of permits for Title V and State Facility Permits.

**Item 3.3**
Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

**Condition 4: Permit modifications, suspensions or revocations by the Department**
**Applicable State Requirement: 6 NYCRR 621.13**

**Item 4.1:**
The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

a) materially false or inaccurate statements in the permit application or supporting papers;
b) failure by the permittee to comply with any terms or conditions of the permit;
c) exceeding the scope of the project as described in the permit application;
d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

**Condition 5: Submission of application for permit modification or renewal - REGION 2 HEADQUARTERS**
**Applicable State Requirement: 6 NYCRR 621.6 (a)**

**Item 5.1:**
Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator
Region 2 Headquarters
Division of Environmental Permits
1 Hunters Point Plaza, 4740 21st Street
Long Island City, NY 11101-5407
(718) 482-4997

**Permit ID: 2-6206-00032/00004** **Facility DEC ID: 2620600032**

**Permit Under the Environmental Conservation Law (ECL)**

**ARTICLE 19: AIR POLLUTION CONTROL - AIR STATE FACILITY PERMIT**

**IDENTIFICATION INFORMATION**

Permit Issued To:NYC HEALTH & HOSPITALS CORP
125 Worth St
New York, NY 10013-4006

Facility: NYC-HH - NEW BELLEVUE HOSPITAL-462 1 AV
462 FIRST AVE
NEW YORK, NY 10016

Authorized Activity By Standard Industrial Classification Code:
8062 - GENERAL MEDICAL & SURGICAL HOSPITALS

Permit Effective Date: Permit Expiration Date:

## PAGE LOCATION OF CONDITIONS

**PAGE**

**FEDERALLY ENFORCEABLE CONDITIONS**
**Facility Level**
6 1 6 NYCRR Subpart 201-7: Facility Permissible Emissions
6 *2 6 NYCRR Subpart 201-7: Capping Monitoring Condition
8 3 6 NYCRR 202-1.2: Notification
8 4 6 NYCRR 211.2: Visible Emissions Limited
8 5 6 NYCRR 225-1.2 (d): Compliance Demonstration
9 6 6 NYCRR 225-1.6 (f): Compliance Demonstration
10 7 6 NYCRR 227-1.3 (c): Compliance Demonstration
10 8 40CFR 60, NSPS Subpart IIII: Applicability
10 9 40CFR 60, NSPS Subpart JJJJ: Applicability
11 10 40CFR 63, Subpart ZZZZ: Engines at Area sources of HAP
**Emission Unit Level**

**EU=U-00002**
11 11 6 NYCRR 227-1.4 (a): Compliance Demonstration
12 12 40CFR 60.7(a), NSPS Subpart A: Date of construction notification - If a COM is not used.

**EU=U-00002,Proc=CHP**
13 13 40CFR 60.8(a), NSPS Subpart A: Performance testing timeline.

**STATE ONLY ENFORCEABLE CONDITIONS**
**Facility Level**
15 14 ECL 19-0301: Contaminant List
15 15 6 NYCRR 201-1.4: Malfunctions and Start-up/Shutdown Activities
16 16 6 NYCRR Subpart 201-5: Emission Unit Definition
17 17 6 NYCRR Subpart 201-5: Compliance Demonstration
18 18 6 NYCRR Subpart 201-5: Compliance Demonstration
19 19 6 NYCRR Subpart 201-5: Compliance Demonstration
20 20 6 NYCRR 201-5.2 (c): Renewal deadlines for state facility permits
20 21 6 NYCRR 201-5.3 (c): Compliance Demonstration
21 22 6 NYCRR 211.1: Air pollution prohibited
21 23 6 NYCRR 253-1.4: Compliance Demonstration
22 24 6 NYCRR 253-1.7: Compliance Demonstration
**Emission Unit Level**
23 25 6 NYCRR Subpart 201-5: Emission Point Definition By Emission Unit
24 26 6 NYCRR Subpart 201-5: Process Definition By Emission Unit

NOTE: * preceding the condition number indicates capping.

## FEDERALLY ENFORCEABLE CONDITIONS
****** Facility Level ******

### NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS
**This section contains terms and conditions which are federally enforceable. Permittees may also have other obligations under regulations of general applicability**

**Item A:** **Sealing - 6 NYCRR 200.5**

The Commissioner may seal an air contamination source to prevent its operation if compliance with 6 NYCRR Chapter III is not met within the time provided by an order of the Commissioner issued in the case of the violation. Sealing means labeling or tagging a source to notify any person that operation of the source is prohibited, and also includes physical means of preventing the operation of an air contamination source without resulting in destruction of any equipment associated with such source, and includes, but is not limited to, bolting, chaining or wiring shut control panels, apertures or conduits associated with such source.

No person shall operate any air contamination source sealed by the Commissioner in accordance with this section unless a modification has been made which enables such source to comply with all requirements applicable to such modification.

Unless authorized by the Commissioner, no person shall remove or alter any seal affixed to any contamination source in accordance with this section.

**Item B:** **Acceptable Ambient Air Quality - 6 NYCRR 200.6**

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

**Item C:** **Maintenance of Equipment - 6 NYCRR 200.7**

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

**Item D:** **Unpermitted Emission Sources - 6 NYCRR 201-1.2**

(a) Except as otherwise provided by this Part, construction or

operation of a new, modified or existing air contamination source without a registration or permit issued pursuant to this Part is prohibited.

(b) If an existing facility or emission source was subject to the permitting requirements of this Part at the time of construction or modification, and the owner or operator failed to apply for a permit or registration as described in this Part, the owner or operator must apply for a permit or registration in accordance with the provisions of this Part. The facility or emission source is subject to all regulations that were applicable to it at the time of construction or modification and any subsequent requirements applicable to existing emission sources.

**Item E: Recycling and Salvage - 6 NYCRR 201-1.7**

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of 6 NYCRR.

**Item F: Prohibition of Reintroduction of Collected Contaminants to the Air - 6 NYCRR 201-1.8**

No person shall unnecessarily remove, handle, or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

**Item G: Proof of Eligibility for Sources Defined as Exempt Activities - 6 NYCRR 201-3.2 (a)**

The owner and/or operator of an emission source or unit that is eligible to be exempt, may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

**Item H: Proof of Eligibility for Sources Defined as Trivial Activities - 6 NYCRR 201-3.3 (a)**

The owner and/or operator of an emission source or unit that is listed as being trivial in 6 NYCRR Part 201 may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart

201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

**Item I: Required Emission Tests - 6 NYCRR 202-1.1**

An acceptable report of measured emissions shall be submitted, as may be required by the Commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation. Failure to submit a report acceptable to the Commissioner within the time stated shall be sufficient reason for the Commissioner to suspend or deny an operating permit. Notification and acceptable procedures are specified in 6 NYCRR Subpart 202-1.

**Item J: Open Fires Prohibitions - 6 NYCRR 215.2**

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

**Item K: Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

**Item L: Federally Enforceable Requirements - 40 CFR 70.6 (b)**

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**FEDERAL APPLICABLE REQUIREMENTS**
**The following conditions are federally enforceable.**

**Permit ID: 2-6206-00032/00004** **Facility DEC ID: 2620600032**

**Condition 1: Facility Permissible Emissions**
**Effective for entire length of Permit**

**Applicable Federal Requirement:6 NYCRR Subpart 201-7**

**Item 1.1:**
The sum of emissions from the emission units specified in this permit shall not equal or exceed the following
Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 0NY210-00-0 PTE: 49,800 pounds per year
Name: OXIDES OF NITROGEN

**Condition 2: Capping Monitoring Condition**
**Effective for entire length of Permit**

**Applicable Federal Requirement:6 NYCRR Subpart 201-7**

**Item 2.1:**
Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR Subpart 201-6
6 NYCRR Subpart 231-2

**Item 2.2:**
Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 2.3:**
The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 2.4:**
On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 2.5:**
The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 2.6:**
The Compliance Demonstration activity will be performed for the facility:
The Compliance Demonstration applies to:

Emission Unit: U-00002
Process: CHP Emission Source: J0007

Emission Unit: U-00002
Process: CHP Emission Source: J0008

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 2.7:**
Compliance Demonstration shall include the following monitoring:

Capping: Yes
Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE
Monitoring Description:
The facility owner or operator shall limit emissions of Oxides of Nitrogen (NOx) to less than 49800 pounds (24.9 tons) per year on a rolling 12-month total basis.

The facility owner or operator shall calculate monthly and rolling 12-month total NOx emissions (including exempt sources) using the following formula:

(A x E1) + (B x E2) = monthly NOx emissions (pounds)

Where:
A = the emission factor (24.5 lb/mmscf) for natural gas fired in co-generation engines based on proposed emission limit of 0.0733 g/bHp-hr. Emission limit must be verified by stack test once every ten years.
E1 = monthly total natural gas fired in two Caterpillar G3516H engines (J0007 and J0008) in mmscf.

B = the latest emission factor (0.438 lbs/gal) for diesel fuel fired in large stationary engines (AP-42 Table 3.4-1);
E2 = monthly total diesel fuel fired in large stationary emergency engine generators ( 4 x Caterpillar C27, 2 x Caterpillar D399, 1 x Caterpillar 3512C, 1 x Cummins DFHD-5622268, and 1 x MTU 16V000 DS20000), in gallons.

The facility owner or operator shall maintain a record of each monthly and rolling 12-month total calculation performed pursuant to this condition and all data used when making the calculation.

All records kept pursuant to this condition shall be maintained at the

facility for a period of at least five years and must be provided to the Department upon request.

The facility owner or operator shall prepare and submit an annual capping certification to the Department. Each certification shall contain the monthly and rolling 12-month total NOx emissions calculated pursuant to this condition.

In addition, the report shall contain a summary of the data used to perform the calculations.

Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 49800 pounds per year
Monitoring Frequency: MONTHLY
Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
Subsequent reports are due every 12 calendar month(s).

**Condition 3: Notification**
**Effective for entire length of Permit**

**Applicable Federal Requirement:6 NYCRR 202-1.2**

**Item 3.1:**
A person who is required by the commissioner to submit a stack test report shall notify the commissioner, in writing, not less than 30 days prior to the test, of the time and date of the test. Such notification shall also include the acceptable procedures to be used to stack test including sampling and analytical procedures. Such person shall allow the commissioner, or his representative, free access to observe stack testing being conducted by such person.

**Condition 4: Visible Emissions Limited**
**Effective for entire length of Permit**

**Applicable Federal Requirement:6 NYCRR 211.2**

**Item 4.1:**
Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

**Condition 5: Compliance Demonstration**
**Effective for entire length of Permit**

**Applicable Federal Requirement:6 NYCRR 225-1.2 (d)**

**Item 5.1:**
The Compliance Demonstration activity will be performed for the Facility.

**Item 5.2:**
Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS
Monitoring Description:

Owners or operators of emission sources that fire distillate oil are limited to a 0.0015 percent sulfur content by weight of the fuel. Compliance with the sulfur-in-fuel limitation is based on fuel vendor receipts. All fuel vendor receipts must be maintained on site or at a Department approved alternative location for a minimum of five years.

Note - Process sources and incinerators must comply with the above requirements on or after July 1, 2023.

Work Practice Type: PARAMETER OF PROCESS MATERIAL
Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL
Parameter Monitored: SULFUR CONTENT
Upper Permit Limit: 0.0015 percent by weight
Monitoring Frequency: PER DELIVERY
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME
(INSTANTANEOUS/DISCRETE OR GRAB)
Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

**Condition 6: Compliance Demonstration**
**Effective for entire length of Permit**

**Applicable Federal Requirement:6 NYCRR 225-1.6 (f)**

**Item 6.1:**
The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 6.2:**
Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

The owner or operator must maintain records of excess emissions. The owner or operator must submit a written report of the fuel sulfur content exceeding the applicable sulfur-in-fuel limitation, measured emissions exceeding the applicable sulfur-in-fuel limitation, measured emissions exceeding the applicable equivalent emission rate, and the nature and cause of such exceedances if known, for each calendar quarter, within 30 days after the end of any quarterly period in which an exceedance[s] takes place. These records must be kept on site or at a Department approved alternative location for a minimum of five years.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 7: Compliance Demonstration**
**Effective for entire length of Permit**

**Applicable Federal Requirement:6 NYCRR 227-1.3 (c)**

**Item 7.1:**
The Compliance Demonstration activity will be performed for the Facility.

**Item 7.2:**
Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:
The owner or operator of a stationary combustion installation must perform an annual tune-up on each emission source subject to 6 NYCRR Subpart 227-1. Records of the tune-up shall be maintained at the facility or at a Department approved alternative location for a minimum of five years. The records shall, at a minimum, include the date the tune-up(s) occurred and the details of the tune-up procedures for each emission source.

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
Subsequent reports are due every 12 calendar month(s).

**Condition 8: Applicability**
**Effective for entire length of Permit**

**Applicable Federal Requirement:40CFR 60, NSPS Subpart IIII**

**Item 8.1:**
Facilities that have stationary compression ignition internal combustion engines must comply with applicable portions of 40 CFR 60 Subpart IIII.

**Condition 9: Applicability**
**Effective for entire length of Permit**

**Applicable Federal Requirement:40CFR 60, NSPS Subpart JJJJ**

**Item 9.1:**
This Condition applies to:

Emission Unit: U00002
Process: CHP Emission Source: J0007

Emission Unit: U00002
Process: CHP Emission Source: J0008

**Item 9.2:**
Facilities that have stationary spark ignition internal combustion engines must comply with applicable portions of 40 CFR 60 Subpart JJJJ.

**Condition 10: Engines at Area sources of HAP**
**Effective for entire length of Permit**

**Applicable Federal Requirement:40CFR 63, Subpart ZZZZ**

**Item 10.1:**
This Condition applies to:

Emission Unit: U00002
Process: CHP Emission Source: J0007

Emission Unit: U00002
Process: CHP Emission Source: J0008

**Item 10.2:**
Internal combustion engines, constructed or re-constructed on or after June 12, 2006, that meet the requirements of 40 CFR 60 Subpart IIII or Subpart JJJJ meet the requirements of 40 CFR 63 Subpart ZZZZ.

****** Emission Unit Level ******

**Condition 11: Compliance Demonstration**
**Effective for entire length of Permit**

**Applicable Federal Requirement:6 NYCRR 227-1.4 (a)**

**Item 11.1:**
The Compliance Demonstration activity will be performed for:

Emission Unit: U-00002

**Item 11.2:**
Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE
Monitoring Description:
No owner or operator of a stationary combustion installation, at an Air State facility subject to this Subpart which is permitted to fire

only natural gas, shall operate an emission source which exhibits greater than 20 percent opacity (based on a six minute average), except for one 6 minute period per hour of not more than 27 percent opacity. The owner or operator will conduct a Method 9 test upon the request of the Department. A report of the results of the test will be submitted to the Department within 30 days of the completion of the Method 9 test. All records generated by the permittee must be maintained at the facility or at an alternative location approved by the Department for a minimum of five years.

Parameter Monitored: OPACITY
Upper Permit Limit: 20 percent
Reference Test Method: 40 CFR 60, Appendix A, Method 9
Monitoring Frequency: UPON REQUEST OF REGULATORY AGENCY
Averaging Method: 6-MINUTE AVERAGE (METHOD 9)
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
Subsequent reports are due every 12 calendar month(s).

**Condition 12: Date of construction notification - If a COM is not used.**
**Effective for entire length of Permit**

**Applicable Federal Requirement:40CFR 60.7(a), NSPS Subpart A**

**Item 12.1:**
This Condition applies to:

Emission Unit: U00002 Emission Point: EP004
Process: CHP Emission Source: J0007

Emission Unit: U00002 Emission Point: EP004
Process: CHP Emission Source: J0008

**Item 12.1:**
This Condition applies to Emission Unit: U-00002

**Item 12.2.3:**
Any owner or operator subject to this part shall furnish the Administrator with the following information:

1) a notification of the date construction or reconstruction commenced, post marked no later than 30 days after such date;

2) [reserved]

3) a notification of the actual date of initial start up, post marked within 15 days after such date;

4) a notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless the

change is specifically exempted under this part. The notice shall be post marked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capability of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional information regarding the change;

5) a notification of the date upon which the demonstration of continuous monitoring system performance commences, post marked not less than 30 days prior to such date;

6) a notification of the anticipated date for conducting the opacity observations, post marked not less than 30 days prior to such date.

**Condition 13: Performance testing timeline.**
**Effective for entire length of Permit**

**Applicable Federal Requirement:40CFR 60.8(a), NSPS Subpart A**

**Item 13.1:**
This Condition applies to:

Emission Unit: U00002
Process: CHP Emission Source: J0007

Emission Unit: U00002
Process: CHP Emission Source: J0008

**Item 13.1:**
This Condition applies to Emission Unit: U-00002
Process: CHP

**Item 13.2.3:**
Within 60 days after achieving the maximum production rate, but not later than 180 days after initial startup of the facility, the owner or operator of the facility shall conduct performance testing and provide the results of such tests, in a written report, to the Administrator.

## STATE ONLY ENFORCEABLE CONDITIONS
****** Facility Level ******

### NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS
**This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability**

**Item A: Emergency Defense - 6 NYCRR 201-1.5**

An emergency, as defined in 6 NYCRR subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) an emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;
(2) the equipment at the facility was being properly operated and maintained;
(3) during the period of the emergency the facility owner or operator took all reasonable steps to minimize the levels of emissions that exceeded the emission standards, or other requirements in the permit; and
(4) the facility owner or operator notified the department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and any corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or malfunction provision contained in any applicable requirement.

Item B: **Public Access to Recordkeeping for Facilities With State Facility Permits - 6 NYCRR 201-1.10 (a)**
Where facility owners and/or operators keep records pursuant to compliance with the requirements of 6 NYCRR Subpart 201-5.4, and/or the emission capping requirements of 6 NYCRR Subpart 201-7, the Department will make such records available to the public upon request in accordance with 6 NYCRR Part 616 - Public Access to Records. Facility owners and/or operators must submit the records required to comply with the request within sixty working days of written notification by the Department.

Item C: **General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**STATE ONLY APPLICABLE REQUIREMENTS**

**The following conditions are state only enforceable.**

**Condition 14: Contaminant List**
**Effective for entire length of Permit**

**Applicable State Requirement:ECL 19-0301**

**Item 14.1:**
Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 000630-08-0
Name: CARBON MONOXIDE

CAS No: 0NY210-00-0
Name: OXIDES OF NITROGEN

CAS No: 0NY998-00-0
Name: VOC

**Condition 15: Malfunctions and Start-up/Shutdown Activities**
**Effective for entire length of Permit**

**Applicable State Requirement:6 NYCRR 201-1.4**

**Item 15.1:**
(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the

emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

(b) The facility owner or operator shall compile and maintain records of all equipment maintenance and start-up/shutdown activities when they are expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when required by a permit condition or upon request by the department. Such reports shall state whether an exceedance occurred and if it was unavoidable, include the time, frequency and duration of the exceedance, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous monitoring and quarterly reporting requirements need not submit additional reports of exceedances to the department.

(c) In the event that air contaminant emissions exceed any applicable emission standard due to a malfunction, the facility owner or operator shall notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. In addition, the facility owner or operator shall compile and maintain a record of all malfunctions. Such records shall be maintained at the facility for a period of at least five years and must be made available to the department upon request. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, the air contaminants emitted, and the resulting emission rates and/or opacity.

(d) The department may also require the facility owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

**Condition 16: Emission Unit Definition**
**Effective for entire length of Permit**

**Applicable State Requirement:6 NYCRR Subpart 201-5**

**Item 16.1:**
The facility is authorized to perform regulated processes under this permit for:
Emission Unit: U-00002
Emission Unit Description:
This emission unit consists of two (2) natural gas fired co-generation engines - Caterpillar G3516H, each rated at 1982 kW, exhausting through two seperate stacks.

Building(s): ED

**Condition 17: Compliance Demonstration**
**Effective for entire length of Permit**

**Applicable State Requirement:6 NYCRR Subpart 201-5**

**Item 17.1:**
The Compliance Demonstration activity will be performed for the facility:
The Compliance Demonstration applies to:

Emission Unit: U-00002
Process: CHP Emission Source: J0007

Emission Unit: U-00002
Process: CHP Emission Source: J0008

Regulated Contaminant(s):
CAS No: 0NY998-00-0 VOC

**Item 17.2:**
Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING
Monitoring Description:
VOC emission factor of 0.102 g/bHp-hr for natural gas fired in cogeneration engines (J0007 and J0008) must be demonstrated through stack testing. This emission factor was used to determine that the total facility-wide VOC emissions remain below the Title V permit threshold of 25 tons per year. If the VOC emission rate is found to exceed the emission limit then the facility must demonstrate compliance with it's Air State Facility status by submitting relevant operational records and calculations.

Within 60 days after achieving the maximum production rate, but not later than 180 days after initial startup of the facility, the owner or operator of the facility shall conduct performance testing and provide the results of such tests, in a written report, to the Department to verify compliance with VOC emission limit.

After the initial testing, subsequent stack testing shall be conducted once every ten years to verify compliance.

The facility must submit to the Department an approvable stack test protocol at least 60 days prior to any stack test. Facility must perform stack test based on approved stack test protocol, and within 60 days of performing the test, submit the stack test report for Department’s approval.

The facility shall keep all records on-site for a minimum period of five years and records must be available to the Department upon

request.

Upper Permit Limit: 0.102 grams per brake horsepower-hour
Reference Test Method: 40 CFR 60 Appendix A 25A and 18
Monitoring Frequency: ONCE EVERY TEN YEARS
Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 18: Compliance Demonstration**
**Effective for entire length of Permit**

**Applicable State Requirement:6 NYCRR Subpart 201-5**

**Item 18.1:**
The Compliance Demonstration activity will be performed for the facility:
The Compliance Demonstration applies to:

Emission Unit: U-00002
Process: CHP Emission Source: J0007

Emission Unit: U-00002
Process: CHP Emission Source: J0008

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 18.2:**
Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING
Monitoring Description:
NOx emission factor of 0.0733 g/bHp-hr for natural gas fired in cogeneration engines (J0007 and J0008) must be demonstrated through stack testing. This emission factor was used to determine that the total facility-wide NOx emissions remain below the Title V permit threshold of 25 tons per year. If the NOx emission rate is found to exceed the emission limit then the facility must demonstrate compliance with it's Air State Facility status by submitting relevant operational records and calculations.

Within 60 days after achieving the maximum production rate, but not later than 180 days after initial startup of the facility, the owner or operator of the facility shall conduct performance testing and provide the results of such tests, in a written report, to the Department to verify compliance with NOx emission limit.

After the initial testing, subsequent stack testing shall be conducted once every ten years to verify compliance.

The facility must submit to the Department an approvable stack test

protocol at least 60 days prior to any stack test. Facility must perform stack test based on approved stack test protocol, and within 60 days of performing the test, submit the stack test report for Department's approval.

The facility shall keep all records on-site for a minimum period of five years and records must be available to the Department upon request.

Upper Permit Limit: 0.0733 grams per brake horsepower-hour
Reference Test Method: 40 CFR Appendix A Method 7E
Monitoring Frequency: ONCE EVERY TEN YEARS
Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 19: Compliance Demonstration**
**Effective for entire length of Permit**

**Applicable State Requirement:6 NYCRR Subpart 201-5**

**Item 19.1:**
The Compliance Demonstration activity will be performed for the facility:
The Compliance Demonstration applies to:

Emission Unit: U-00002
Process: CHP Emission Source: J0007

Emission Unit: U-00002
Process: CHP Emission Source: J0008

Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

**Item 19.2:**
Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING
Monitoring Description:
CO emission factor of 0.275 g/bHp-hr for natural gas fired in cogeneration engines (J0007 and J0008) must be demonstrated through stack testing. This emission factor was used to determine that the total facility-wide CO emissions remain below the Title V permit threshold of 100 tons per year. If the CO emission rate is found to exceed the emission limit then the facility must demonstrate compliance with it's Air State Facility status by submitting relevant operational records and calculations.

Within 60 days after achieving the maximum production rate, but not later than 180 days after initial startup of the facility, the owner or operator of the facility shall conduct performance testing and

provide the results of such tests, in a written report, to the Department to verify compliance with CO emission limit.

After the initial testing, subsequent stack testing shall be conducted once every ten years to verify compliance.

The facility must submit to the Department an approvable stack test protocol at least 60 days prior to any stack test. Facility must perform stack test based on approved stack test protocol, and within 60 days of performing the test, submit the stack test report for Department's approval.

The facility shall keep all records on-site for a minimum period of five years and records must be available to the Department upon request.

Upper Permit Limit: 0.275 grams per brake horsepower-hour
Reference Test Method: 40 CFR Appendix A Method
Monitoring Frequency: ONCE EVERY TEN YEARS
Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 20: Renewal deadlines for state facility permits**
**Effective for entire length of Permit**

**Applicable State Requirement:6 NYCRR 201-5.2 (c)**

**Item 20.1:**
The owner or operator of a facility having an issued state facility permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

**Condition 21: Compliance Demonstration**
**Effective for entire length of Permit**

**Applicable State Requirement:6 NYCRR 201-5.3 (c)**

**Item 21.1:**
The Compliance Demonstration activity will be performed for the Facility.

**Item 21.2:**
Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:
Any reports or submissions required by this permit shall be submitted to the Regional Air Pollution Control Engineer (RAPCE) at the following address:

Division of Air Resources
NYS Dept. of Environmental Conservation
Region 2
47-40 21st St.
Long Island City, NY 11101

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION
Averaging Method: AVERAGING METHOD - SEE MONITORING DESCRIPTION
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 22: Air pollution prohibited**
**Effective for entire length of Permit**

**Applicable State Requirement:6 NYCRR 211.1**

**Item 22.1:**
No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

**Condition 23: Compliance Demonstration**
**Effective for entire length of Permit**

**Applicable State Requirement:6 NYCRR 253-1.4**

**Item 23.1:**
The Compliance Demonstration activity will be performed for the Facility.

**Item 23.2:**
Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

Owners or operators of facilities that contain emission sources specified in Section 253-1.2 of this Part must monitor emissions and submit emissions data reports to the Department, except as otherwise provided in Part 253, following the requirements specified in 40 CFR Sections 98.3 through 98.4 (Amended November 18, 2024) (see Table 1, section 200.9 of this Title).

Owners or operators shall submit emissions data reports and any revisions to the reports through the NYS e-GGRT platform, or any other reporting tool approved by the Department that will guarantee transmittal and receipt of data and information required by Part 253. Each owner or operator must submit an emissions data report for the

previous calendar year no later than June 1st of the current calendar year.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 24: Compliance Demonstration**
**Effective for entire length of Permit**

**Applicable State Requirement:6 NYCRR 253-1.7**

**Item 24.1:**
The Compliance Demonstration activity will be performed for the Facility.

**Item 24.2:**
Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

The owner or operator of each emission source that is required to report greenhouse gases under this Part, which emits a minimum of 10,000 metric tons (MT) of CO2e but less than 25,000 MT of CO2e, must keep records as required by 40 CFR Sections 98.3(g) through (h) (Amended November 18, 2024) (see Table 1, Section 200.9 of this Title) and as specified in this Subpart or as prescribed in the relevant Section(s) of Subpart 2 of this Part.

The following emission sources must maintain records on-site or at an alternative location approved by the Department for a period of five years from the date of emissions data report certification:

Emission sources that do not meet the threshold requirements pursuant to paragraph 253-1.2(f) of this Part or are not required to verify their emissions pursuant to Subpart 253-4 of this Part during any reporting year, must maintain required records for a period of five years from the date of certification.

Copies of any records or other materials maintained under the requirements of 40 CFR Part 98 (Amended November 18, 2024) (see Table 1, section 200.9 of this Title) or this Part must be made available to the Department upon request within 14 days of receipt of such request by the designated representative of the reporting entity, unless a different schedule is agreed to by the Department.

Emission sources must maintain the following records, including but not limited to:

(1) Information used to quantify or report emissions and product data in the emissions data report, underlying monitoring and metering data, invoices of receipts or deliveries, sales transaction data,

calculation methods, protocols used, analysis results, calibration records, electricity transaction data, and other relevant information.
(2) A list of units, operations, processes, and activities for which GHG emissions were calculated.
(3) The data used to calculate the GHG emissions for each unit, operation, process and activity categorized by fuel or material type. These data include but are not limited to:

(i) the GHG emissions calculations and methods used;
(ii) analytical results for the development of site-specific emission factors;
(iii) the results of all required analyses for high heat value, carbon content, and other required fuel or feed stock parameters;
(iv) emissions data and input data, industrial product data and associated inputs; data associated with thermal energy provided, sold, purchased, or acquired; and data associated with electricity provided, sold, purchased, or acquired must be sufficient to allow for verification of each emissions data report; and
(v) any facility operating data or process information used for the GHG calculations.

(4) The annual GHG emissions data reports.
(5) Missing data computations for each missing data event, the cause of each event and the corrective actions taken to restore malfunctioning monitoring equipment.
(6) Continuous monitoring system records. The results of all required certification and quality assurance tests for continuous monitoring systems, fuel flow meters, and other instrumentation used to provide data for the GHG emissions reported under this Part.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION
Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

****** Emission Unit Level ******

**Condition 25: Emission Point Definition By Emission Unit**
**Effective for entire length of Permit**

**Applicable State Requirement:6 NYCRR Subpart 201-5**

**Item 25.1:**
The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00002

Emission Point: EP003
Height (ft.): 185 Diameter (in.): 24
NYTMN (km.): 4510.2 NYTME (km.): 586.5 Building: ED

Emission Point: EP004
Height (ft.): 185 Diameter (in.): 24
NYTMN (km.): 4510.2 NYTME (km.): 586.5 Building: ED

**Condition 26: Process Definition By Emission Unit**
**Effective for entire length of Permit**

**Applicable State Requirement:6 NYCRR Subpart 201-5**

**Item 26.1:**
This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00002
Process: CHP Source Classification Code: 2-03-002-04

Emission Source/Control: J0007 - Combustion
Design Capacity: 1,982 kilowatts

Emission Source/Control: J0008 - Combustion
Design Capacity: 1,982 kilowatts

Summary of Compliance Requirements

*** THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF THE MONITORING REQUIREMENTS.
READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. ***

DEC ID 2620600032 Facility NYC-HH - NEW BELLEVUE HOSPITAL-462 1 AV

Location 462 FIRST AVE NEW YORK, NY 10016

Permit ID 2-6206-00032/00004 Application Recv'd 05/05/2023 Renewal No: 1

Permit Type ASF Status Working Copy

Compliance Assurance Monitoring

| Cond Num | Monitored Parameter / Regulated Contaminant / Process Material | Lower Limit / Upper Limit / Units | Activity Type / Reporting Frequency / Monitoring Frequency / Averaging Method |
|---|---|---|---|
| 2 | OXIDES OF NITROGEN | 49800 | MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE |
| CAP | OXIDES OF NITROGEN | pounds per year | ANNUALLY (CALENDAR) |
| | **** | | MONTHLY |
| | THE FACILITY OWNER OR OPERATOR SHALL LIMIT EMISSIONS OF OXIDES OF NITROGEN (NOX) TO LESS THAN 49800 POUNDS (24.9 TONS) PER YEAR ON A ROLLING 12-MONTH TOTAL BASIS. | | ANNUAL MAXIMUM ROLLED MONTHLY |
| | THE FACILITY OWNER OR OPERATOR SHALL CALCULATE MONTHLY AND ROLLING 12-MONTH TOTAL NOX EMISSIONS (INCLUDING EXEMPT SOURCES) USING THE FOLLOWING FORMULA: | | |
| | (A X E1) + (B X E2) = MONTHLY NOX EMISSIONS (POUNDS) | | |
| | WHERE:<br>A = THE EMISSION FACTOR (24.5 LB/MMSCF) FOR NATURAL GAS FIRED IN CO-GENERATION ENGINES BASED ON PROPOSED EMISSION LIMIT OF 0.0733 G/BHP-HR. EMISSION LIMIT MUST BE VERIFIED BY STACK TEST ONCE EVERY TEN YEARS.<br>E1 = MONTHLY TOTAL NATURAL GAS FIRED IN TWO CATERPILLAR G3516H ENGINES (J0007 AND J0008) IN MMSCF. | | |
| | B = THE LATEST EMISSION FACTOR (0.438 LBS/GAL) FOR DIESEL FUEL FIRED IN LARGE STATIONARY ENGINES (AP-42 TABLE 3.4-1);<br>E2 = MONTHLY TOTAL DIESEL FUEL FIRED IN LARGE STATIONARY EMERGENCY ENGINE GENERATORS ( 4 X CATERPILLAR C27, 2 X CATERPILLAR D399, 1 X CATERPILLAR 3512C, 1 X CUMMINS DFHD-5622268, AND 1 X MTU 16V000 DS20000), IN GALLONS. | | |
| | THE FACILITY OWNER OR OPERATOR SHALL MAINTAIN A RECORD OF EACH MONTHLY AND ROLLING 12-MONTH TOTAL CALCULATION PERFORMED PURSUANT TO THIS CONDITION AND ALL DATA USED WHEN MAKING THE CALCULATION. | | |
| | ALL RECORDS KEPT PURSUANT TO THIS CONDITION SHALL BE MAINTAINED AT THE FACILITY FOR A PERIOD OF AT LEAST FIVE YEARS AND MUST BE PROVIDED TO THE DEPARTMENT UPON REQUEST. | | |
| | THE FACILITY OWNER OR OPERATOR SHALL PREPARE AND SUBMIT AN ANNUAL CAPPING CERTIFICATION TO THE DEPARTMENT. EACH CERTIFICATION SHALL CONTAIN THE MONTHLY AND ROLLING 12-MONTH TOTAL NOX EMISSIONS CALCULATED PURSUANT TO THIS CONDITION. | | |
| | IN ADDITION, THE REPORT SHALL CONTAIN A SUMMARY OF THE DATA USED TO PERFORM THE CALCULATIONS. | | |
| | Following Emission unit(EU), Emission point(EP), Process(PROC), Emission Source(ES) apply to this monitoring:<br>EU: U-00002/PROC: CHP/ES: J0008<br>EU: U-00002/PROC: CHP/ES: J0007 | | |

Summary of Compliance Requirements

*** THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF THE MONITORING REQUIREMENTS.
READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. ***

DEC ID 2620600032 Facility NYC-HH - NEW BELLEVUE HOSPITAL-462 1 AV

Location 462 FIRST AVE NEW YORK, NY 10016

Permit ID 2-6206-00032/00004 Application Recv'd 05/05/2023 Renewal No: 1

Permit Type ASF Status Working Copy

Compliance Assurance Monitoring

| Cond Num | Monitored Parameter / Regulated Contaminant / Process Material | Lower Limit | Upper Limit | Units | Activity Type / Reporting Frequency / Monitoring Frequency / Averaging Method |
|---|---|---|---|---|---|
| 5 | SULFUR CONTENT<br>****<br>DISTILLATES - NUMBER 1 AND NUMBER 2 OIL | | 0.0015 | percent by weight | WORK PRACTICE INVOLVING SPECIFIC OPERATIONS<br>UPON REQUEST BY REGULATORY AGENCY<br>PER DELIVERY<br>MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR |
| | OWNERS OR OPERATORS OF EMISSION SOURCES THAT FIRE DISTILLATE OIL ARE LIMITED TO A 0.0015 PERCENT SULFUR CONTENT BY WEIGHT OF THE FUEL. COMPLIANCE WITH THE SULFUR-IN-FUEL LIMITATION IS BASED ON FUEL VENDOR RECEIPTS. ALL FUEL VENDOR RECEIPTS MUST BE MAINTAINED ON SITE OR AT A DEPARTMENT APPROVED ALTERNATIVE LOCATION FOR A MINIMUM OF FIVE YEARS.<br><br>NOTE - PROCESS SOURCES AND INCINERATORS MUST COMPLY WITH THE ABOVE REQUIREMENTS ON OR AFTER JULY 1, 2023. | | | | |
| 6 | ****<br>OXIDES OF NITROGEN<br>**** | | | | RECORD KEEPING/MAINTENANCE PROCEDURES<br>AS REQUIRED - SEE MONITORING DESCRIPTION<br>AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION<br>**** |
| | THE OWNER OR OPERATOR MUST MAINTAIN RECORDS OF EXCESS EMISSIONS. THE OWNER OR OPERATOR MUST SUBMIT A WRITTEN REPORT OF THE FUEL SULFUR CONTENT EXCEEDING THE APPLICABLE SULFUR-IN-FUEL LIMITATION, MEASURED EMISSIONS EXCEEDING THE APPLICABLE SULFUR-IN-FUEL LIMITATION, MEASURED EMISSIONS EXCEEDING THE APPLICABLE EQUIVALENT EMISSION RATE, AND THE NATURE AND CAUSE OF SUCH EXCEEDANCES IF KNOWN, FOR EACH CALENDAR QUARTER, WITHIN 30 DAYS AFTER THE END OF ANY QUARTERLY PERIOD IN WHICH AN EXCEEDANCE[S] TAKES PLACE. THESE RECORDS MUST BE KEPT ON SITE OR AT A DEPARTMENT APPROVED ALTERNATIVE LOCATION FOR A MINIMUM OF FIVE YEARS. | | | | |

Summary of Compliance Requirements

*** THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF THE MONITORING REQUIREMENTS.
READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. ***

DEC ID 2620600032 Facility NYC-HH - NEW BELLEVUE HOSPITAL-462 1 AV

Location 462 FIRST AVE NEW YORK, NY 10016

Permit ID 2-6206-00032/00004 Application Recv'd 05/05/2023 Renewal No: 1

Permit Type ASF Status Working Copy

Compliance Assurance Monitoring

| Cond Num | Monitored Parameter / Regulated Contaminant / Process Material | Lower Limit | Upper Limit | Units | Activity Type / Reporting Frequency / Monitoring Frequency / Averaging Method |
|---|---|---|---|---|---|
| 7 | **** / **** / **** | | | | RECORD KEEPING/MAINTENANCE PROCEDURES / ANNUALLY (CALENDAR) / ANNUALLY / **** |
| | THE OWNER OR OPERATOR OF A STATIONARY COMBUSTION INSTALLATION MUST PERFORM AN ANNUAL TUNE-UP ON EACH EMISSION SOURCE SUBJECT TO 6 NYCRR SUBPART 227-1. RECORDS OF THE TUNE-UP SHALL BE MAINTAINED AT THE FACILITY OR AT A DEPARTMENT APPROVED ALTERNATIVE LOCATION FOR A MINIMUM OF FIVE YEARS. THE RECORDS SHALL, AT A MINIMUM, INCLUDE THE DATE THE TUNE-UP(S) OCCURRED AND THE DETAILS OF THE TUNE-UP PROCEDURES FOR EACH EMISSION SOURCE. | | | | |

Emission Unit: U-00002

| Cond Num | Monitored Parameter / Regulated Contaminant / Process Material | Lower Limit | Upper Limit | Units | Activity Type / Reporting Frequency / Monitoring Frequency / Averaging Method |
|---|---|---|---|---|---|
| 11 | OPACITY / **** / **** | | 20 | percent | MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE / ANNUALLY (CALENDAR) / UPON REQUEST OF REGULATORY AGENCY / 6-MINUTE AVERAGE (METHOD 9) |
| | NO OWNER OR OPERATOR OF A STATIONARY COMBUSTION INSTALLATION, AT AN AIR STATE FACILITY SUBJECT TO THIS SUBPART WHICH IS PERMITTED TO FIRE ONLY NATURAL GAS, SHALL OPERATE AN EMISSION SOURCE WHICH EXHIBITS GREATER THAN 20 PERCENT OPACITY (BASED ON A SIX MINUTE AVERAGE), EXCEPT FOR ONE 6 MINUTE PERIOD PER HOUR OF NOT MORE THAN 27 PERCENT OPACITY. THE OWNER OR OPERATOR WILL CONDUCT A METHOD 9 TEST UPON THE REQUEST OF THE DEPARTMENT. A REPORT OF THE RESULTS OF THE TEST WILL BE SUBMITTED TO THE DEPARTMENT WITHIN 30 DAYS OF THE COMPLETION OF THE METHOD 9 TEST. ALL RECORDS GENERATED BY THE PERMITTEE MUST BE MAINTAINED AT THE FACILITY OR AT AN ALTERNATIVE LOCATION APPROVED BY THE DEPARTMENT FOR A MINIMUM OF FIVE YEARS. | | | | |

Summary of Compliance Requirements

*** THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF THE MONITORING REQUIREMENTS.
READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. ***

DEC ID 2620600032 Facility NYC-HH - NEW BELLEVUE HOSPITAL-462 1 AV

Location 462 FIRST AVE NEW YORK, NY 10016

Permit ID 2-6206-00032/00004 Application Recv'd 05/05/2023 Renewal No: 1

Permit Type ASF Status Working Copy

Compliance Assurance Monitoring

| Cond Num | Monitored Parameter / Regulated Contaminant / Process Material | Lower Limit | Upper Limit | Units | Activity Type / Reporting Frequency / Monitoring Frequency / Averaging Method |
|---|---|---|---|---|---|
| 17 | **** VOC **** | | 0.102 | grams per brake horsepower-hour | INTERMITTENT EMISSION TESTING<br>AS REQUIRED - SEE MONITORING DESCRIPTION<br>ONCE EVERY TEN YEARS<br>AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED |

VOC EMISSION FACTOR OF 0.102 G/BHP-HR FOR NATURAL GAS FIRED IN COGENERATION ENGINES (J0007 AND J0008) MUST BE DEMONSTRATED THROUGH STACK TESTING. THIS EMISSION FACTOR WAS USED TO DETERMINE THAT THE TOTAL FACILITY-WIDE VOC EMISSIONS REMAIN BELOW THE TITLE V PERMIT THRESHOLD OF 25 TONS PER YEAR. IF THE VOC EMISSION RATE IS FOUND TO EXCEED THE EMISSION LIMIT THEN THE FACILITY MUST DEMONSTRATE COMPLIANCE WITH IT'S AIR STATE FACILITY STATUS BY SUBMITTING RELEVANT OPERATIONAL RECORDS AND CALCULATIONS.

WITHIN 60 DAYS AFTER ACHIEVING THE MAXIMUM PRODUCTION RATE, BUT NOT LATER THAN 180 DAYS AFTER INITIAL STARTUP OF THE FACILITY, THE OWNER OR OPERATOR OF THE FACILITY SHALL CONDUCT PERFORMANCE TESTING AND PROVIDE THE RESULTS OF SUCH TESTS, IN A WRITTEN REPORT, TO THE DEPARTMENT TO VERIFY COMPLIANCE WITH VOC EMISSION LIMIT.

AFTER THE INITIAL TESTING, SUBSEQUENT STACK TESTING SHALL BE CONDUCTED ONCE EVERY TEN YEARS TO VERIFY COMPLIANCE.

THE FACILITY MUST SUBMIT TO THE DEPARTMENT AN APPROVABLE STACK TEST PROTOCOL AT LEAST 60 DAYS PRIOR TO ANY STACK TEST. FACILITY MUST PERFORM STACK TEST BASED ON APPROVED STACK TEST PROTOCOL, AND WITHIN 60 DAYS OF PERFORMING THE TEST, SUBMIT THE STACK TEST REPORT FOR DEPARTMENT'S APPROVAL.

THE FACILITY SHALL KEEP ALL RECORDS ON-SITE FOR A MINIMUM PERIOD OF FIVE YEARS AND RECORDS MUST BE AVAILABLE TO THE DEPARTMENT UPON REQUEST.

Following Emission unit(EU), Emission point(EP), Process(PROC), Emission Source(ES) apply to this monitoring:
EU: U-00002/PROC: CHP/ES: J0008
EU: U-00002/PROC: CHP/ES: J0007

Summary of Compliance Requirements

*** THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF THE MONITORING REQUIREMENTS.
READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. ***

DEC ID 2620600032 Facility NYC-HH - NEW BELLEVUE HOSPITAL-462 1 AV

Location 462 FIRST AVE NEW YORK, NY 10016

Permit ID 2-6206-00032/00004 Application Recv'd 05/05/2023 Renewal No: 1

Permit Type ASF Status Working Copy

Compliance Assurance Monitoring

| Cond Num | Monitored Parameter / Regulated Contaminant / Process Material | Lower Limit | Upper Limit | Units | Activity Type / Reporting Frequency / Monitoring Frequency / Averaging Method |
|---|---|---|---|---|---|
| 18 | **** | | 0.0733 | | INTERMITTENT EMISSION TESTING |
| | OXIDES OF NITROGEN | | | grams per brake horsepower-hour | AS REQUIRED - SEE MONITORING DESCRIPTION |
| | **** | | | | ONCE EVERY TEN YEARS |
| | | | | | AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED |

NOX EMISSION FACTOR OF 0.0733 G/BHP-HR FOR NATURAL GAS FIRED IN COGENERATION ENGINES (J0007 AND J0008) MUST BE DEMONSTRATED THROUGH STACK TESTING. THIS EMISSION FACTOR WAS USED TO DETERMINE THAT THE TOTAL FACILITY-WIDE NOX EMISSIONS REMAIN BELOW THE TITLE V PERMIT THRESHOLD OF 25 TONS PER YEAR. IF THE NOX EMISSION RATE IS FOUND TO EXCEED THE EMISSION LIMIT THEN THE FACILITY MUST DEMONSTRATE COMPLIANCE WITH IT'S AIR STATE FACILITY STATUS BY SUBMITTING RELEVANT OPERATIONAL RECORDS AND CALCULATIONS.

WITHIN 60 DAYS AFTER ACHIEVING THE MAXIMUM PRODUCTION RATE, BUT NOT LATER THAN 180 DAYS AFTER INITIAL STARTUP OF THE FACILITY, THE OWNER OR OPERATOR OF THE FACILITY SHALL CONDUCT PERFORMANCE TESTING AND PROVIDE THE RESULTS OF SUCH TESTS, IN A WRITTEN REPORT, TO THE DEPARTMENT TO VERIFY COMPLIANCE WITH NOX EMISSION LIMIT.

AFTER THE INITIAL TESTING, SUBSEQUENT STACK TESTING SHALL BE CONDUCTED ONCE EVERY TEN YEARS TO VERIFY COMPLIANCE.

THE FACILITY MUST SUBMIT TO THE DEPARTMENT AN APPROVABLE STACK TEST PROTOCOL AT LEAST 60 DAYS PRIOR TO ANY STACK TEST. FACILITY MUST PERFORM STACK TEST BASED ON APPROVED STACK TEST PROTOCOL, AND WITHIN 60 DAYS OF PERFORMING THE TEST, SUBMIT THE STACK TEST REPORT FOR DEPARTMENT'S APPROVAL.

THE FACILITY SHALL KEEP ALL RECORDS ON-SITE FOR A MINIMUM PERIOD OF FIVE YEARS AND RECORDS MUST BE AVAILABLE TO THE DEPARTMENT UPON REQUEST.

Following Emission unit(EU), Emission point(EP), Process(PROC), Emission Source(ES) apply to this monitoring:
EU: U-00002/PROC: CHP/ES: J0007
EU: U-00002/PROC: CHP/ES: J0008

Summary of Compliance Requirements

*** THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF THE MONITORING REQUIREMENTS.
READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. ***

DEC ID 2620600032 Facility NYC-HH - NEW BELLEVUE HOSPITAL-462 1 AV

Location 462 FIRST AVE NEW YORK, NY 10016

Permit ID 2-6206-00032/00004 Application Recv'd 05/05/2023 Renewal No: 1

Permit Type ASF Status Working Copy

Compliance Assurance Monitoring

| Cond Num | Monitored Parameter / Regulated Contaminant / Process Material | Lower Limit | Upper Limit | Units | Activity Type / Reporting Frequency / Monitoring Frequency / Averaging Method |
|---|---|---|---|---|---|
| 19 | **** CARBON MONOXIDE **** | | 0.275 | grams per brake horsepower-hour | INTERMITTENT EMISSION TESTING<br>AS REQUIRED - SEE MONITORING DESCRIPTION<br>ONCE EVERY TEN YEARS<br>AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED |

CO EMISSION FACTOR OF 0.275 G/BHP-HR FOR NATURAL GAS FIRED IN COGENERATION ENGINES (J0007 AND J0008) MUST BE DEMONSTRATED THROUGH STACK TESTING. THIS EMISSION FACTOR WAS USED TO DETERMINE THAT THE TOTAL FACILITY-WIDE CO EMISSIONS REMAIN BELOW THE TITLE V PERMIT THRESHOLD OF 100 TONS PER YEAR. IF THE CO EMISSION RATE IS FOUND TO EXCEED THE EMISSION LIMIT THEN THE FACILITY MUST DEMONSTRATE COMPLIANCE WITH IT'S AIR STATE FACILITY STATUS BY SUBMITTING RELEVANT OPERATIONAL RECORDS AND CALCULATIONS.

WITHIN 60 DAYS AFTER ACHIEVING THE MAXIMUM PRODUCTION RATE, BUT NOT LATER THAN 180 DAYS AFTER INITIAL STARTUP OF THE FACILITY, THE OWNER OR OPERATOR OF THE FACILITY SHALL CONDUCT PERFORMANCE TESTING AND PROVIDE THE RESULTS OF SUCH TESTS, IN A WRITTEN REPORT, TO THE DEPARTMENT TO VERIFY COMPLIANCE WITH CO EMISSION LIMIT.

AFTER THE INITIAL TESTING, SUBSEQUENT STACK TESTING SHALL BE CONDUCTED ONCE EVERY TEN YEARS TO VERIFY COMPLIANCE.

THE FACILITY MUST SUBMIT TO THE DEPARTMENT AN APPROVABLE STACK TEST PROTOCOL AT LEAST 60 DAYS PRIOR TO ANY STACK TEST. FACILITY MUST PERFORM STACK TEST BASED ON APPROVED STACK TEST PROTOCOL, AND WITHIN 60 DAYS OF PERFORMING THE TEST, SUBMIT THE STACK TEST REPORT FOR DEPARTMENT'S APPROVAL.

THE FACILITY SHALL KEEP ALL RECORDS ON-SITE FOR A MINIMUM PERIOD OF FIVE YEARS AND RECORDS MUST BE AVAILABLE TO THE DEPARTMENT UPON REQUEST.

Following Emission unit(EU), Emission point(EP), Process(PROC), Emission Source(ES) apply to this monitoring:
EU: U-00002/PROC: CHP/ES: J0007
EU: U-00002/PROC: CHP/ES: J0008

Summary of Compliance Requirements

*** THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF THE MONITORING REQUIREMENTS.
READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. ***

DEC ID 2620600032 Facility NYC-HH - NEW BELLEVUE HOSPITAL-462 1 AV

Location 462 FIRST AVE NEW YORK, NY 10016

Permit ID 2-6206-00032/00004 Application Recv'd 05/05/2023 Renewal No: 1

Permit Type ASF Status Working Copy

| Cond Num | Compliance Assurance Monitoring<br>Monitored Parameter<br>Regulated Contaminant<br>Process Material | Lower Limit / Upper Limit / Units | Activity Type<br>Reporting Frequency<br>Monitoring Frequency<br>Averaging Method |
|---|---|---|---|
| 21 | ****<br>****<br>****<br>ANY REPORTS OR SUBMISSIONS REQUIRED BY THIS PERMIT SHALL BE SUBMITTED TO THE REGIONAL AIR POLLUTION CONTROL ENGINEER (RAPCE) AT THE FOLLOWING ADDRESS:<br>DIVISION OF AIR RESOURCES<br>NYS DEPT. OF ENVIRONMENTAL CONSERVATION<br>REGION 2<br>47-40 21ST ST.<br>LONG ISLAND CITY, NY 11101 | | RECORD KEEPING/MAINTENANCE PROCEDURES<br>AS REQUIRED - SEE MONITORING DESCRIPTION<br>AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION<br>AVERAGING METHOD - SEE MONITORING DESCRIPTION |
| 23 | ****<br>****<br>****<br>OWNERS OR OPERATORS OF FACILITIES THAT CONTAIN EMISSION SOURCES SPECIFIED IN SECTION 253-1.2 OF THIS PART MUST MONITOR EMISSIONS AND SUBMIT EMISSIONS DATA REPORTS TO THE DEPARTMENT, EXCEPT AS OTHERWISE PROVIDED IN PART 253, FOLLOWING THE REQUIREMENTS SPECIFIED IN 40 CFR SECTIONS 98.3 THROUGH 98.4 (AMENDED NOVEMBER 18, 2024) (SEE TABLE 1, SECTION 200.9 OF THIS TITLE).<br>OWNERS OR OPERATORS SHALL SUBMIT EMISSIONS DATA REPORTS AND ANY REVISIONS TO THE REPORTS THROUGH THE NYS E-GGRT PLATFORM, OR ANY OTHER REPORTING TOOL APPROVED BY THE DEPARTMENT THAT WILL GUARANTEE TRANSMITTAL AND RECEIPT OF DATA AND INFORMATION REQUIRED BY PART 253. EACH OWNER OR OPERATOR MUST SUBMIT AN EMISSIONS DATA REPORT FOR THE PREVIOUS CALENDAR YEAR NO LATER THAN JUNE 1ST OF THE CURRENT CALENDAR YEAR. | | RECORD KEEPING/MAINTENANCE PROCEDURES<br>AS REQUIRED - SEE MONITORING DESCRIPTION<br>AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION<br>**** |

Summary of Compliance Requirements

*** THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF THE MONITORING REQUIREMENTS.
READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. ***

DEC ID 2620600032 Facility NYC-HH - NEW BELLEVUE HOSPITAL-462 1 AV

Location 462 FIRST AVE NEW YORK, NY 10016

Permit ID 2-6206-00032/00004 Application Recv'd 05/05/2023 Renewal No: 1

Permit Type ASF Status Working Copy

| Compliance Assurance Monitoring | | | | |
|---|---|---|---|---|
| | Monitored Parameter | | | Activity Type |
| | Regulated Contaminant | Lower Limit | Upper Limit | Reporting Frequency |
| Cond Num | Process Material | Units | | Monitoring Frequency / Averaging Method |

| | | |
|---|---|---|
| 24 | **** | RECORD KEEPING/MAINTENANCE PROCEDURES |
| | **** | UPON REQUEST BY REGULATORY AGENCY |
| | **** | AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION |
| | THE OWNER OR OPERATOR OF EACH EMISSION SOURCE THAT IS REQUIRED TO REPORT GREENHOUSE GASES UNDER THIS PART, WHICH EMITS A MINIMUM OF 10,000 METRIC TONS (MT) OF CO2E BUT LESS THAN 25,000 MT OF CO2E, MUST KEEP RECORDS AS REQUIRED BY 40 CFR SECTIONS 98.3(G) THROUGH (H) (AMENDED NOVEMBER 18, 2024) (SEE TABLE 1, SECTION 200.9 OF THIS TITLE) AND AS SPECIFIED IN THIS SUBPART OR AS PRESCRIBED IN THE RELEVANT SECTION(S) OF SUBPART 2 OF THIS PART.<br><br>THE FOLLOWING EMISSION SOURCES MUST MAINTAIN RECORDS ON-SITE OR AT AN ALTERNATIVE LOCATION APPROVED BY THE DEPARTMENT FOR A PERIOD OF FIVE YEARS FROM THE DATE OF EMISSIONS DATA REPORT CERTIFICATION:<br><br>EMISSION SOURCES THAT DO NOT MEET THE THRESHOLD REQUIREMENTS PURSUANT TO PARAGRAPH 253-1.2(F) OF THIS PART OR ARE NOT REQUIRED TO VERIFY THEIR EMISSIONS PURSUANT TO SUBPART 253-4 OF THIS PART DURING ANY REPORTING YEAR, MUST MAINTAIN REQUIRED RECORDS FOR A PERIOD OF FIVE YEARS FROM THE DATE OF CERTIFICATION.<br><br>COPIES OF ANY RECORDS OR OTHER MATERIALS MAINTAINED UNDER THE REQUIREMENTS OF 40 CFR PART 98 (AMENDED NOVEMBER 18, 2024) (SEE TABLE 1, SECTION 200.9 OF THIS TITLE) OR THIS PART MUST BE MADE AVAILABLE TO THE DEPARTMENT UPON REQUEST WITHIN 14 DAYS OF RECEIPT OF SUCH REQUEST BY THE DESIGNATED REPRESENTATIVE OF THE REPORTING ENTITY, UNLESS A DIFFERENT SCHEDULE IS AGREED TO BY THE DEPARTMENT.<br><br>EMISSION SOURCES MUST MAINTAIN THE FOLLOWING RECORDS, INCLUDING BUT NOT LIMITED TO:<br><br>(1) INFORMATION USED TO QUANTIFY OR REPORT EMISSIONS AND PRODUCT DATA IN THE EMISSIONS DATA REPORT, UNDERLYING MONITORING AND METERING DATA, INVOICES OF RECEIPTS OR DELIVERIES, SALES TRANSACTION DATA, CALCULATION METHODS, PROTOCOLS USED, ANALYSIS RESULTS, CALIBRATION RECORDS, ELECTRICITY TRANSACTION DATA, AND OTHER RELEVANT INFORMATION.<br>(2) A LIST OF UNITS, OPERATIONS, PROCESSES, AND ACTIVITIES FOR WHICH GHG EMISSIONS WERE CALCULATED.<br>(3) THE DATA USED TO CALCULATE THE GHG EMISSIONS FOR EACH UNIT, OPERATION, PROCESS AND ACTIVITY CATEGORIZED BY FUEL OR MATERIAL TYPE. THESE DATA INCLUDE BUT ARE NOT LIMITED TO:<br><br>(I) THE GHG EMISSIONS CALCULATIONS AND METHODS USED;<br>(II) ANALYTICAL RESULTS FOR THE DEVELOPMENT OF SITE-SPECIFIC EMISSION FACTORS;<br>(III) THE RESULTS OF ALL REQUIRED ANALYSES FOR HIGH HEAT VALUE, CARBON CONTENT, AND OTHER REQUIRED FUEL OR FEED STOCK PARAMETERS;<br>(IV) EMISSIONS DATA AND INPUT DATA, INDUSTRIAL PRODUCT DATA AND ASSOCIATED INPUTS; DATA ASSOCIATED WITH THERMAL ENERGY PROVIDED, SOLD, PURCHASED, OR ACQUIRED; AND DATA ASSOCIATED WITH ELECTRICITY PROVIDED, SOLD, PURCHASED, OR ACQUIRED MUST BE SUFFICIENT TO ALLOW FOR VERIFICATION OF EACH EMISSIONS DATA REPORT; AND<br>(V) ANY FACILITY OPERATING DATA OR PROCESS INFORMATION USED FOR THE GHG CALCULATIONS | |

*** THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF THE MONITORING REQUIREMENTS.
READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. ***

DEC ID 2620600032 Facility NYC-HH - NEW BELLEVUE HOSPITAL-462 1 AV

Location 462 FIRST AVE NEW YORK, NY 10016

Permit ID 2-6206-00032/00004 Application Recv'd 05/05/2023 Renewal No: 1

Permit Type ASF Status Working Copy

Compliance Assurance Monitoring

| Cond Num | Monitored Parameter / Regulated Contaminant / Process Material | Lower Limit | Upper Limit | Units | Activity Type / Reporting Frequency / Monitoring Frequency / Averaging Method |
|---|---|---|---|---|---|
| | (4) ANY FACILITY OPERATING DATA OR PROCESS INFORMATION USED FOR THE GHG CALCULATIONS | | | | |
| | (4) THE ANNUAL GHG EMISSIONS DATA REPORTS.<br>(5) MISSING DATA COMPUTATIONS FOR EACH MISSING DATA EVENT, THE CAUSE OF EACH EVENT AND THE CORRECTIVE ACTIONS TAKEN TO RESTORE MALFUNCTIONING MONITORING EQUIPMENT.<br>(6) CONTINUOUS MONITORING SYSTEM RECORDS. THE RESULTS OF ALL REQUIRED CERTIFICATION AND QUALITY ASSURANCE TESTS FOR CONTINUOUS MONITORING SYSTEMS, FUEL FLOW METERS, AND OTHER INSTRUMENTATION USED TO PROVIDE DATA FOR THE GHG EMISSIONS REPORTED UNDER THIS PART. | | | | |

**Summary of Compliance Requirements**

***** THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF FACILITY PERMISSIBLE EMISSIONS. READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. *****

**DEC ID** 2620600032 **Facility** NYC-HH - NEW BELLEVUE HOSPITAL-462 1 AV

**Location** 462 FIRST AVE NEW YORK, NY 10016

**Permit ID** 2-6206-00032/00004 **Application Recv'd** 05/05/2023 **Renewal No:** 1

**Permit Type** ASF **Status** Working Copy

**Facility Permissible Emissions**

| | | | |
|---|---|---|---|
| 000630-08-0 | CARBON MONOXIDE | | |
| 0NY210-00-0 | OXIDES OF NITROGEN | 49800 | pounds per year |
| 0NY998-00-0 | VOC | | |